

Center for physical measurements - CFM

Laboratory for ecology in toxicology - LET

Rep. No: **LET 20070306/I**

Date: 1.10. 2007

REPORT OF MEASUREMENTS

1. Client: **NEBULUS d.o.o., ZBILJSKA CESTA 4, 1215 MEDVODE**
2. Measured object: **Smoking cabin SMOKEPOINT on location Obrtna ul. 3, HORJUL**
3. Number and date of contract: **the confirmation of the offer 4.9.2007**
4. Purpose of the measurement: **the control measurements**
5. Date of measurement: **13.9. 2007**
6. Date of previous measurements:
7. Type of measurements: **CONCENTRATION OF NICOTINE**
INSIDE SMOKING CABIN
8. Sphere of activity: **/**

Measurements performed by:

A.STERMENSZKY, univ. dipl. inž. kem. teh.

UROŠ LAJEVEC, kem. teh.

Report prepared by:

A.STERMENSZKY, univ. dipl. inž. kem. teh.

Report approved by the head of LET:

dr.B.PODKRAJŠEK, univ. dipl. kem.



1. TASK

Company Nebulus d.o.o., Medvode, instructed the control measurements of concentrations of chemical substances, which are a result of smoking in the cabin SmokePoint. Cabin of size 129.8 x 208.3 x 254cm, fitted with a system for cleaning the air filter HEPA H13 and charcoal adsorption aired material, is for the purpose of measurements installed in a room with a volume of 48.6 m³ (4 x 4.5 x 2,7m). The room is free of artificial ventilation. During the two hour measurements from one to four smokers were present in the smoking cabin. The total number of smoked cigarettes was 32. The room was at the time of sampling not ventilated, except for a moment through the door on arrival or departure of smokers. In this report, we present the results of measurements of concentration of nicotine inside the smoking cabin..

2. PRINCIPLE OF THE MEASUREMENTS

A measured volume of sample air is drawn through sorbent tube with XAD-2. The collected vapour is desorbed by a solvent and the solution is analysed with a gas chromatograph Agilent 6890N equipped with mass selective detector.

3. RESULTS OR THE MEASUREMENTS

The concentration of nicotine at a time and in terms of measuring reached the value 94 µg/m³ of air.



Report reviewed by:

dr.Boštjan Podkrajšek,univ.dipl.kem.

The document is issued in one original copy and one copy. One copy is kept in the archives ZVD for five years.